

DEPARTMENT OF TRANSPORTATION**DIVISION OF ENGINEERING SERVICES**

Office of Structural Materials

Quality Assurance and Source Inspection



Bay Area Branch
690 Walnut Ave. St. 150
Vallejo, CA 94592-1133
(707) 649-5453
(707) 649-5493

Contract #: 04-0120F4Cty: SF/Ala Rte: 80 PM: 13.2/13.9File #: 69.28**WELDING INSPECTION REPORT****Resident Engineer:** Siegenthaler, Peter**Address:** 333 Burma Road**City:** Oakland, CA 94607**Report No:** WIR-017510**Date Inspected:** 29-Sep-2010**Project Name:** SAS Superstructure**OSM Arrival Time:** 1900**Prime Contractor:** American Bridge/Fluor Enterprises, a JV**OSM Departure Time:** 700**Contractor:** Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island **Location:** Shanghai, China**CWI Name:** See below**CWI Present:** Yes No**Inspected CWI report:** Yes No N/A**Rod Oven in Use:** Yes No N/A**Electrode to specification:** Yes No N/A**Weld Procedures Followed:** Yes No N/A**Qualified Welders:** Yes No N/A**Verified Joint Fit-up:** Yes No N/A**Approved Drawings:** Yes No N/A**Approved WPS:** Yes No N/A**Delayed / Cancelled:** Yes No N/A**Bridge No:** 34-0006**Component:** Tower and OBG Components**Summary of Items Observed:**

On this date Caltrans OSM Quality Assurance Inspector (QA Inspector) George Goulet was present during the times noted above for observations relative to the work being performed.

Bay 11

This QA Inspector randomly observed the following work in progress in Bay 11:

FCAW welding of weld joints BK004A-020-A5-056, 057, 062, 063, 076, 077 located on PCMK BK004-020. Welders were identified as 042218, 049220. QC was identified as ZPMC CWI Yu Dong Ping (QC1). Assisting QC1 at this location and appearing to be monitoring the welding and recording data was ZPMC QC Xu Jie (QCA1), who was not a CWI. Welding variables recorded by QCA1 appeared to comply with WPS-B-T-2132.

SMAW repair of weld joint ND1-BRSA5-2-7A located on PCMK north tower, lift 5. Welder was identified as 044541. QC was identified as QC1. Welding variables recorded by QC1 appeared to comply with WPS-B-T-3213-TC-U4b.

Bay 10

This QA Inspector randomly observed no apparent work in progress in Bay 10.

OBG Trial Assembly Area

This QA Inspector randomly observed the following work in progress in the Trial Assembly Area:

WELDING INSPECTION REPORT

(Continued Page 2 of 2)


SMAW welding of temporary alignment plates located on OBG 10CW/11AW, across the transverse joint, side plate to side plate, north (counterweight) side. Welder was identified as 046709. QC was identified as ZPMC CWI Liu Hua Jie (QC2). Welding variables recorded by QC2 appeared to comply with WPS-B-P-2114.

Heavy Dock

This QA Inspector randomly observed the following on the Heavy Dock:

All 4 towers' lift 3 were connected and positioned vertically on a base pedestal at end of the Heavy Dock. East, south, west, and north towers, lift 4 were positioned on top of east, south, west, and north towers, lift 3, respectively, on the Heavy Dock. The personnel access elevator made several stops at 131M, 139M, and 143M elevation levels and sounds of drilling could be heard from the deck of the Heavy Dock. The ZPMC 1300 ton floating crane was moored to the Heavy Dock and sitting idle.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.



Summary of Conversations:

No significant conversations.

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Micheal Ng, 159-2184-5703, who represents the Office of Structural Materials for your project.

Inspected By:	Goulet, George	Quality Assurance Inspector
Reviewed By:	Clifford, William	QA Reviewer
